

CERTIFICATE OF CONFORMITY

No. DZC.522.98.2026
Issue No. 01 of 2026.08.18*Name and address of
the certificate holder:*Zakład Aparatury Elektrycznej ERGOM Sp. z o.o.
10 Nowe Sady Str.,
94-102 Łódź, Poland*Name of the product:*

Terminal lugs / through connectors

Type:

CKOR 10-240 / CKL 10-240

*Manufacturer:*Zakład Aparatury Elektrycznej ERGOM Sp. z o.o.
10 Nowe Sady Str.,
94-102 Łódź, Poland*Parameters:*

According to the appendix

*The product meets
requirements of:*

EN IEC 61238-1-1:2019, EN IEC 61238-1-3:2019

*According to the
reports made by:*BBJ-SEP; Institute of Power Engineering – National Research Institute;
ZAE ERGOM*Numbers of the type test
reports:*LA-22.098/E, LA-22.097/E; EWP/35/E/2017-1, EWP/35/E/2017-2,
EWP/35/E/2017-3, EWP/35/E/2017-5; ERGOM/02/01/2017,
ERGOM/03/01/2017, ERGOM/04/01/2017, ERGOM/05/01/2017*Period of validity:*from 18th of August 2026 until 17th of August 2029

The right to use the certificate of conformity within its validity period applies only to:

- those copies that have identical features, construction and equipment as the product samples submitted for testing
- certificate holder or his authorized representative

*The list of technical data is included in the appendices to the certificate of conformity.**Number of appendices: 1*THE SYSTEM OF PRODUCT CERTIFICATION PC_1a (Program 1a acc. to PN-EN ISO/IEC 17067:2014-01)
(product parameters confirmed by type test)DEPUTY DIRECTOR OF
INSTITUTE OF POWER ENGINEERING
– NATIONAL RESEARCH INSTITUTE



Instytut
Energetyki



AC 117

APPENDIX TO THE CERTIFICATE OF CONFORMITY

No. DZC.522.98.2026

Issue No. 01 of 2026.08.18

LIST OF EVIDENCED PARAMETERS

Name / Cu connector type	Terminal lug ¹⁾ CKOR 10-240	Through connector ¹⁾ CKL 10-240
Class - electrical - mechanical	A 1	A 1
Construction / cross-section of Cu cables / conductors [mm ²]	RMC ²⁾ , RM, SM / 10÷240	RMC ²⁾ , RM, SM / 10÷240
Initial scatter δ ³⁾	$\leq 0,30$	$\leq 0,30$
Mean scatter β ⁴⁾	$\leq 0,30$	$\leq 0,30$
Resistance factor ratio λ ⁵⁾	$\leq 2,0$	$\leq 2,0$
Change in resistance factor D ⁶⁾	$\leq 0,15$	$\leq 0,15$
Maximum temperature $\theta_{\max}$ ⁷⁾	$\leq \theta_{\text{ref}}$	$\leq \theta_{\text{ref}}$
Permissible tensile force [N]	$\leq 60 \times A$ ⁸⁾ Cu	$\leq 60 \times A$ ⁸⁾ Cu

NOTES:

- ¹⁾ Terminal lugs of type CKOR 10-240 has common name of "Tubular cable lugs for compacted wires, CKOR type". Through connectors of type CKL 10-240 has common name of " Butt splice cable connectors for compacted wires, CKL type".
- ²⁾ In the technical documentation of cable and wire manufacturers, the RMC designation is also known as RMV
- ³⁾ The average value of the resistance factors of six connectors (lugs) before the first heating cycle.
- ⁴⁾ The average value of the resistance factors of six connectors (lugs) calculated from last 11 measurements readings. It specifies if all connectors (lugs) of given type are characterized by similar changes in resistance during the heat cycles.
- ⁵⁾ Resistance factor ratio of tested connector (lug) during the heat cycle test in relation to the initial resistance factor.
- ⁶⁾ The value specifies the size of the resistance factor change based on last 11 measurements readings.
- ⁷⁾ Temperature of the connector (lug) referenced to the temperature of the reference section
- ⁸⁾ Nominal cross-sectional area

