



**Instytut  
Energetyki**

**INSTITUTE OF POWER ENGINEERING  
– NATIONAL RESEARCH INSTITUTE**  
Certification and Inspection Department  
Mory 8, 01-330 Warsaw  
phone +48 22 34 51 200  
instytut.energetyki@ien.com.pl



AC 117

# **CERTIFICATE OF CONFORMITY**

**No. DZC.522.32.2025**  
**Issue No. 01 of 2025.04.18**

*Name and address of  
the certificate holder:*

**Zakład Aparatury Elektrycznej ERGOM Sp. z o.o.**  
**Nowe Sady 10**  
**94-102 Łódź, Poland**

*Name of the product:*

**Through connectors**

*Type:*

**LA 16-300**

*Manufacturer:*

**Zakład Aparatury Elektrycznej ERGOM Sp. z o.o.**  
**Nowe Sady 10**  
**94-102 Łódź, Poland**

*Parameters:*

**According to the appendix**

*Application of the product:*

**Connection of aluminium cables with class 2 conductors**

*The product meets  
requirements of:*

**EN IEC 61238-1-1:2019, EN IEC 61238-1-3:2019**

*According to the  
reports made by:*

**Institute of Power Engineering - National Research Institute**

*Numbers of the type test  
reports:*

**EWP/49/E/2015-1, EWP/49/E/2015-2, EWP/57/E/2017-1,  
EWP/57/E/2017-2**

*Period of validity:*

**from 18<sup>th</sup> of April 2025 until 17<sup>th</sup> of April 2028**

The right to use the certificate of conformity within its validity period applies only to:

- these copies that meet the requirements specified above and have the same characteristics (parameters) as the model / product samples submitted for testing
- certificate holder or his authorized representative

The list of evidenced parameters is included in the appendices to the certificate of conformity.

Number of appendices: 1

**THE SYSTEM OF PRODUCT CERTIFICATION PC\_1a (Program 1a acc. to PN-EN ISO/IEC 17067:2014-01)**  
(product parameters confirmed by type test)



pp of the ACTING DIRECTOR OF  
INSTITUTE OF POWER ENGINEERING  
– NATIONAL RESEARCH INSTITUTE

Dariusz Zienkiewicz, M.Sc. Eng

Warsaw, 2025.04.18



## APPENDIX TO THE CERTIFICATE OF CONFORMITY

**No. DZC.522.32.2025**

**Issue No. 01 of 2025.04.18**

### LIST OF EVIDENCED PARAMETERS

Name / Al connector type	Through connector <sup>1)</sup> / LA 16-300
Class - electrical - mechanical	A 1
Construction / cross-section of Al cables / conductors [mm <sup>2</sup> ]	RM 16 ÷ 300
Initial scatter $\delta^{2)}$	$\leq 0,30$
Mean scatter $\beta^{3)}$	$\leq 0,30$
Resistance factor ratio $\lambda^{4)}$	$\leq 2,0$
Change in resistance factor $D^{5)}$	$\leq 0,15$
Maximum temperature $\theta_{\max}^{6)}$	$\leq \theta_{\text{ref}}$
Permissible tensile force [N]	$\leq 40 \times A^{7)} \text{ Al}$

### NOTES:

- 1) <sup>1)</sup> Through connectors LA 16-300 has common name of "Non-tension compression tubular cable connectors, LA... type"
- 2) <sup>2)</sup> The average value of the resistance factors of six connectors (lugs) before the first heating cycle.
- 3) <sup>3)</sup> The average value of the resistance factors of six connectors (lugs) calculated from last eleven measurements readings. It specifies if all connectors (lugs) of given type are characterized by similar changes in resistance during the heat cycles.
- 4) <sup>4)</sup> Resistance factor ratio of tested connector (lug) during the heat cycle test in relation to the initial resistance factor.
- 5) <sup>5)</sup> The value specifies the size of the resistance factor change based on last 11 measurements readings.
- 6) <sup>6)</sup> Temperature of the connector (lug) referenced to the temperature of the reference section.
- 7) <sup>7)</sup> Nominal cross-sectional area.

