

INSTITUTE OF POWER ENGINEERING - NATIONAL RESEARCH INSTITUTE

Certification and Inspection Department

Mory 8, 01-330 Warsaw phone +48 22 34 51 200 instytut.energetyki@ien.com.pl



AC 117

CERTIFICATE OF CONFORMITY

No. DZC.522.32.2025 Issue No. 02 of 2025.07.25

Name and address of the certificate holder:

Zaklad Aparatury Elektrycznej ERGOM Sp. z o.o.

Nowe Sady 10

94-102 Lodz, Poland

Name of the product:

Through connectors

Type:

LA 16-300

Manufacturer:

Zaklad Aparatury Elektrycznej ERGOM Sp. z o.o.

Nowe Sady 10

94-102 Lodz, Poland

Parameters:

According to the appendix

The product meets

requirements of:

EN IEC 61238-1-1:2019, EN IEC 61238-1-3:2019

According to the

reports made by:

Institute of Power Engineering; SEP-BBJ

Numbers of the type test

reports:

EWP/49/E/2015-1, EWP/49/E/2015-2; LA-24.113/E, LA-24.142/E

Period of validity:

from 25^{th} of July 2025 until 17^{th} of April 2028

The right to use the certificate of conformity within its validity period applies only to:

- those copies that have identical features, construction and equipment as the product samples submitted for testing
- certificate holder or his authorized representative

The list of technical data is included in the appendices to the certificate of conformity. Number of appendices: 1

THE SYSTEM OF PRODUCT CERTIFICATION PC_1a (Program 1a acc. to PN-EN ISO/IEC 17067:2014-01) (product parameters confirmed by type test)



Certification Body Manager INSTITUTE OF POWER ENGINEERING – NATIONAL RESEARCH INSTITUTE





APPENDIX TO THE CERTIFICATE OF CONFORMITY No. DZC.522.32.2025

Issue No. 02 of 2025.07.25 LIST OF EVIDENCED PARAMETERS

Name / Al connector type	Through connector ¹⁾ / LA 16-300
Class	
- electrical	A
- mechanical	1
Construction / cross-section of	$RMC^{2)}$, RM, SM /
Al cables / conductors [mm ²]	16 ÷300
Initial scatter $\delta^{3)}$	≤ 0,30
Mean scatter β ⁴⁾	≤ 0,30
Resistance factor ratio λ ⁵⁾	≤ 2,0
Change in resistance factor D ⁶⁾	≤ 0,15
Maximum temperature θ_{max}^{7}	$\leq \theta_{ref}$
Permissible tensile force [N]	$\leq 40 \times A^{8} \text{ Al}$

NOTES:

- 1) ¹⁾ Through connectors LA 16-300 has common name of "Non-tension compression tubular cable connectors, LA... type"
- 2) ²⁾ In the technical documentation of cable and wire manufacturers, the RMC designation is also known as RMV
- 3) ³⁾ The average value of the resistance factors of six connectors (lugs) before the first heating cycle.
- 4) ⁴⁾ The average value of the resistance factors of six connectors (lugs) calculated from last eleven measurements readings. It specifies if all connectors (lugs) of given type are characterized by similar changes in resistance during the heat cycles.
- 5) Sesistance factor ratio of tested connector (lug) during the heat cycle test in relation to the initial resistance factor.
- 6) The value specifies the size of the resistance factor change based on last 11 measurements readings.
- 7) Temperature of the connector (lug) referenced to the temperature of the reference section.
- 8) 8) Nominal cross-sectional area

