



AC 117

INSTYTUT ENERGETYKI
Instytut Badawczy
Certification and Inspection Department
01-330 Warszawa, ul. Mory 8
tel. +48 22 34 51 200
instytut.energetyki@ien.com.pl

CERTIFICATE OF CONFORMITY

No. DZC.522.77.2023

Issue No. 01 of 2023.08.18

Name and address of the certificate holder:

Zakład Aparatury Elektrycznej ERGOM Sp. z o.o.
10 Nowe Sady Str.,
94-102 Łódź, Poland

Name of the product:

Terminal lugs / through connectors

Type:

CKOR 10-240 / CKL 10-240

Manufacturer:

Zakład Aparatury Elektrycznej ERGOM Sp. z o.o.
10 Nowe Sady Str.,
94-102 Łódź, Poland

Parameters and application of the product:

According to appendix
Connection and termination of copper cables with class 2
conductors with parameters according to appendix

The product meets requirements of:

EN IEC 61238-1-1:2019, EN IEC 61238-1-3:2019

According to the reports made by:

BBJ-SEP; Instytut Energetyki; ZAE ERGOM

Number of the test reports:

LA-22.098/E, LA-22.097/E; EWP/35/E/2017-1, EWP/35/E/2017-2,
EWP/35/E/2017-3, EWP/35/E/2017-5; ERGOM/02/01/2017,
ERGOM/03/01/2017, ERGOM/04/01/2017, ERGOM/05/01/2017

Period of validity:

from 18th of August 2023 until 17th of August 2026

The right to use the certificate of conformity within its validity period applies only to:

- these copies that meet the requirements specified above and have the same characteristics (parameters) as the model / product samples submitted for testing,
- certificate holder or his authorized representative.


The list of evidenced parameters is included in the appendices to the certificate of conformity.

Number of appendices: 1

THE SYSTEM OF PRODUCT CERTIFICATION PC_1a (Program 1a acc. to PN-EN ISO/IEC 17067:2014-01)
(product parameters confirmed by type test)



pp of the DIRECTOR OF
INSTYTUT ENERGETYKI


dr hab. Grzegorz Tchorek, prof. IEn

Warsaw, 2023.08.18



AC 117

APPENDIX TO CERTIFICATE OF CONFORMITY
No. DZC.522.77.2023
Issue No. 01 of 2023.08.18

LIST OF EVIDENCED PARAMETERS

Name / Cu connector type	Terminal lug ¹⁾ CKOR 10-240	Through connector ¹⁾ CKL 10-240
Class		
- electrical	A	A
- mechanical	1	1
Construction / cross-section of Cu cables / conductors [mm ²]	RMC ²⁾ , RM, SM / 10÷240	RMC ²⁾ , RM, SM / 10÷240
Initial scatter δ ³⁾	$\leq 0,30$	$\leq 0,30$
Mean scatter β ⁴⁾	$\leq 0,30$	$\leq 0,30$
Resistance factor ratio λ ⁵⁾	$\leq 2,0$	$\leq 2,0$
Change in resistance factor D ⁶⁾	$\leq 0,15$	$\leq 0,15$
Maximum temperature θ_{\max} ⁷⁾	$\leq \theta_{\text{ref}}$	$\leq \theta_{\text{ref}}$
Permissible tensile force [N]	$\leq 60 \times A$ ⁸⁾ Cu	$\leq 60 \times A$ ⁸⁾ Cu

NOTES:

- 1) ¹⁾ Terminal lugs of type CKOR 10-240 has common name of "Tubular ring terminals for compacted wires, CKOR type". Through connectors of type CKL 10-240 has common name of " Butt splice connectors for compacted wires, CKL type".
- 2) ²⁾ In the technical documentation of cable and wire manufacturers, the RMC designation is also known as RMV
- 3) ³⁾ The average value of the resistance factors of six connectors (lugs) before the first heating cycle.
- 4) ⁴⁾ The average value of the resistance factors of six connectors (lugs) calculated from last 11 measurements readings. It specifies if all connectors (lugs) of given type are characterized by similar changes in resistance during the heat cycles.
- 5) ⁵⁾ Resistance factor ratio of tested connector (lug) during the heat cycle test in relation to the initial resistance factor.
- 6) ⁶⁾ The value specifies the size of the resistance factor change based on last 11 measurements readings.
- 7) ⁷⁾ Temperature of the connector (lug) referenced to the temperature of the reference section.
- 8) ⁸⁾ Nominal cross-sectional area

