

CERTIFICATE OF CONFORMITY**No. DZC.522.04.2.2025****Issue No. 01 of 2025.02.21***Name and address of
the certificate holder:***Zakład Aparatury Elektrycznej ERGOM Sp. z o.o.
Nowe Sady 10
94-102 Łódź, Poland***Name of the product:***Terminal lugs / Through connectors***Type:***KOR 10-240 / KL 10-240***Manufacturer:***Zakład Aparatury Elektrycznej ERGOM Sp. z o.o.
Nowe Sady 10
94-102 Łódź, Poland***Parameters:***According to the appendix***Application of the product:***Connection and termination of copper cables with class 2 conductors***The product meets
requirements of:***EN IEC 61238-1-1:2019, EN IEC 61238-1-3:2019***According to the
reports made by:***SEP-BBJ; Instytut Energetyki; ZAE ERGOM***Numbers of the type test
reports:***LA-18.089/2, LA-18.089/1; EWP/35/E/2017-8, EWP/35/E/2017-9,
EWP/35/E/2017-13; ERGOM/10/04/2018, ERGOM/12/04/2018,
ERGOM/14/05/2018***Period of validity:***from 21st of February 2025 until 20th of February 2028**

The right to use the certificate of conformity within its validity period applies only to:

- these copies that meet the requirements specified above and have the same characteristics (parameters) as the model / product samples submitted for testing
- certificate holder or his authorized representative

The list of evidenced parameters is included in the appendices to the certificate of conformity.

Number of appendices: 1

THE SYSTEM OF PRODUCT CERTIFICATION PC_1a (Program 1a acc. to PN-EN ISO/IEC 17067:2014-01)
(product parameters confirmed by type test)



pp of the ACTING DIRECTOR OF
INSTITUTE OF POWER ENGINEERING
– NATIONAL RESEARCH INSTITUTE

Dariusz Zienkiewicz, M.Sc. Eng

Warsaw, 2025.02.21

APPENDIX TO THE CERTIFICATE OF CONFORMITY

No. DZC.522.04.2.2025

Issue No. 01 of 2025.02.21

LIST OF EVIDENCED PARAMETERS

Name / Cu connector type	Terminal lug ¹⁾ / KOR 10-240	Through connector ¹⁾ / KL 10-240
Class - electrical - mechanical	A 1	A 1
Construction / cross-section of Cu cables / conductors [mm ²]	RMC ²⁾ , RM, SM / 10 ÷ 240	RMC ²⁾ , RM, SM / 10 ÷ 240
Initial scatter $\delta^3)$	$\leq 0,30$	$\leq 0,30$
Mean scatter $\beta^4)$	$\leq 0,30$	$\leq 0,30$
Resistance factor ratio $\lambda^5)$	$\leq 2,0$	$\leq 2,0$
Change in resistance factor $D^6)$	$\leq 0,15$	$\leq 0,15$
Maximum temperature $\theta_{\max}^7)$	$\leq \theta_{\text{ref}}$	$\leq \theta_{\text{ref}}$
Permissible tensile force [N]	$\leq 60 \times A^8) \text{ Cu}$	$\leq 60 \times A^8) \text{ Cu}$

NOTES:

- 1) ¹⁾ Terminal lugs of type KOR 10-240 has common name of: Tubular ring terminals, KOR 10-240 type. Through connectors KL 10-240 has common name of: "Butt splice" compression connectors, KL 10-240 type.
- 2) ²⁾ In the technical documentation of cable and wire manufacturers, the RMC designation is also known as RMV.
- 3) ³⁾ The average value of the resistance factors of six connectors (lugs) before the first heating cycle.
- 4) ⁴⁾ The average value of the resistance factors of six connectors (lugs) calculated from last 11 measurements readings. It specifies if all connectors (lugs) of given type are characterized by similar changes in resistance during the heat cycles.
- 5) ⁵⁾ Resistance factor ratio of tested connector (lug) during the heat cycle test in relation to the initial resistance factor.
- 6) ⁶⁾ The value specifies the size of the resistance factor change based on last 11 measurements readings.
- 7) ⁷⁾ Temperature of the connector (lug) referenced to the temperature of the reference section.
- 8) ⁸⁾ Nominal cross-sectional area.

