



AC 117

**INSTYTUT ENERGETYKI**  
Instytut Badawczy  
Certification and Inspection Department  
01-330 Warszawa, ul. Mory 8  
tel. +48 22 34 51 200  
instytut.energetyki@ien.com.pl

# CERTIFICATE OF CONFORMITY

**No. DZC.522.78.1.2023**

**Issue No. 01 of 2023.08.18**

*Name and address of  
the certificate holder:*

Zakład Aparatury Elektrycznej ERGOM Sp. z o.o.  
10 Nowe Sady Str.,  
94-102 Łódź, Poland

*Name of the product:*

Terminal lugs

*Type:*

KORW 25-240

*Manufacturer:*

Zakład Aparatury Elektrycznej ERGOM Sp. z o.o.  
10 Nowe Sady Str.,  
94-102 Łódź, Poland

*Parameters and  
application of the product:*

According to appendix  
Termination of copper cables with class 2 conductors with  
parameters according to appendix

*The product meets  
requirements of:*

EN IEC 61238-1-1:2019, EN IEC 61238-1-3:2019

*According to the  
reports made by:*

Instytut Energetyki; ZAE ERGOM

*Number of the test reports:*

EWP/35/E/2021-29, EWP/35/E/2021-31, EWP/35/E/2021-28,  
EUR.4032.35.2022.R2.PL; ERGOM/47/02/2022, ERGOM/52/03/2022,  
ERGOM/50/03/2022, ERGOM/53/12/2022

*Period of validity:*

from 18<sup>th</sup> of August 2023 until 17<sup>th</sup> of August 2026

The right to use the certificate of conformity within its validity period applies only to:

- these copies that meet the requirements specified above and have the same characteristics (parameters) as the model / product samples submitted for testing,
- certificate holder or his authorized representative.

*The list of evidenced parameters is included in the appendices to the certificate of conformity.*

*Number of appendices: 1*

THE SYSTEM OF PRODUCT CERTIFICATION PC\_1a (Program 1a acc. to PN-EN ISO/IEC 17067:2014-01)  
(product parameters confirmed by type test)



pp of the DIRECTOR OF  
INSTYTUT ENERGETYKI

dr hab. Grzegorz Tchorek, prof. IEn

Warsaw, 2023.08.18



AC 117

**APPENDIX TO CERTIFICATE OF CONFORMITY**  
**No. DZC.522.78.1.2023**  
**Issue No. 01 of 2023.08.18**

**LIST OF EVIDENCED PARAMETERS**

<b>Cu terminal lugs<sup>1)</sup> of type</b>	<b>KORW 25-240 for cables with class 2 conductors</b>
Class - electrical - mechanical	A 1
Construction / cross-section of Cu cables / conductors [mm <sup>2</sup> ]	RMC <sup>2)</sup> , RM, SM / 25÷240
Initial scatter $\delta^3)$	$\leq 0,30$
Mean scatter $\beta^4)$	$\leq 0,30$
Resistance factor ratio $\lambda^5)$	$\leq 2,0$
Change in resistance factor $D^6)$	$\leq 0,15$
Maximum temperature $\theta_{\max}^7)$	$\leq \theta_{\text{ref}}$
Permissible tensile force [N]	$\leq 60 \times A^8)$ Cu

NOTES:

- 1) <sup>1)</sup> Terminal lugs of type KORW 25-240 for cables with class 2 conductors has common name of: "Narrowed" tubular ring terminals, KORW type
- 2) <sup>2)</sup> In the technical documentation of cable and wire manufacturers, the RMC designation is also known as RMV
- 3) <sup>3)</sup> The average value of the resistance factors of six connectors (lugs) before the first heating cycle.
- 4) <sup>4)</sup> The average value of the resistance factors of six connectors (lugs) calculated from last 11 measurements readings. It specifies if all connectors (lugs) of given type are characterized by similar changes in resistance during the heat cycles.
- 5) <sup>5)</sup> Resistance factor ratio of tested connector (lug) during the heat cycle test in relation to the initial resistance factor.
- 6) <sup>6)</sup> The value specifies the size of the resistance factor change based on last 11 measurements readings.
- 7) <sup>7)</sup> Temperature of the connector (lug) referenced to the temperature of the reference section.
- 8) <sup>8)</sup> Nominal cross-sectional area

